Service & Credit Return Form sonova **PHONAK** AudioNova unitron. Information Customer Device **Ship to Account Number:** Date: Adress: Device model / Serial Number State Zip: City: Receiver: (must accompany device) power level / size (0-3) / side (L/R) **Bill to Account Number:** SlimTube: size/side (0-3, L/R) (if included) Adress: Earhook color Custom Ear Piece model / Serial Number City: State Zip: Hearing instrument not included in regali -Roger Direct[™] Installation Information Patient **Patient Name:** Roge, Direct installed in the MarvelTM device? 3rd Party Patient Number: If yes, please select the install method: Purchase Order Number: **Contact Name:** □ Roger X (02) - Pediatric □ Roger iN Microphone or Roger X(03) - Adult Phone Number: **Optional - Country dependant** Request Comments Customer request (CC13 / CC38 / CC39) Add/remove/change option (please specify your request in comments field) Remake / Repair reason Residues (CC17) Broken (CC16) Wax problem Housing □ Shell □ Lock □ Faceplate Removable line Sweat, moisture, humidity Battery door Wheel Wax system Service (CC14) Bent battery contacts Switch / Button Clean & functional check Earhook / Soundtube Receiver wire of C-Shell Lost / damaged (CC25D) Microphone cover Wires inside device / shell Returned to customer unrepaired Cord or cable cracked / frayed Electronic module / faceplate detached Receiver detached from Shell (ITE) (accessories) R Hardware / Components Shell fit (CC23) Not Functioning (CC10) Too visible - protuding / cosmetics Too small - dexterity problem □ Toggle switch □ Push button □ Volume control wheel Tip too long Tip too short (please add a 2nd reason: comfort / (please add 2nd reason: □ Dead □ Display (accessories) dexterity / insertion-removal issue) retention / comfort / dexterity issue) Battery: □ Rechargeable □ Not rechargeable □ High drain □ Stuck Difficult to insert Difficult to remove Too loose poor retention Too tight Connectivity (CC10) Too loose moving in the ear □ FM □ Wireless / Bluetooth Sound bore direction □ Programming problem (HI ↔ Software) □ Telecoil Please mark the problem area Acoustic output response (CC11) Hurts where marked: Occlusion L R □ Shell □ Lock Feedback: Internal (not poor fit) with static jaw with moving jaw Feedback: Venting diameter too large Feedback: Due to shell fit / not airtight by inserting/removing device Feedback: Due to shell fit / not airtight with moving jaw Noisy: crackling / popcorn Noisy: static / hissing Acoustic response too weak Acoustic response too weak after feedback test Intermittent Sound fades in/out

	Distorted			
	Poor acoustic perforn	nances (e.g. venting too la	arge)	
			Return for credit	
	D Quality reason	I D		
L	R Quality reason	L K	L K	

-	auunij rouoon		
	Acoustic / Sound Quality		Cosmetic
	Not functioning		Comfort & Retention
	Too many repair/remake		Exchange form factor
	Not enough benefit		Issue with Flex upgrade

Distorted

	L	R	
			Order fulfilment error
			Overstock / consignment
			Cost related
			Patient can't adapt

1	
	Patient medical problem
	Device medical problem
	Please specify